



Measurement System Analysis

Learning objectives


- To be able to select and use appropriate methods to verify the .
- To know all the methods, and know how to interpret and evaluate their results
- To know the methods' scope of application as well as their limits
- To know approaches for identifying the causes of non-capable measurement processes and be able to make approval decisions

- Definitions and requirements from standards
- Resolution of a display
- Measurement uncertainty of the measurement standard
- Procedure 1 – Systematic error and repeatability
- Procedure 2 – Repeatability and reproducibility
- Procedure 3 – Appraiser-independent systems
- Procedure 4 – Linearity
- Procedure 5 – Stability
- Procedure 6 – Test processes for discretized continuous characteristics
- Procedure 7 – Test processes for discrete characteristics
- Assessment of non-capable measurement and test processes
 - Risk analysis and approval decision
 - Causes of non-capable measurement systems




*Done first, for
content reasons*

Test and measurement



Test and measurement



Even if you can test by measuring, :

- Measurement process capability for continuous characteristics
- Test process capability for discrete characteristics

Quote :

Note: Testing discrete or discretized characteristics is not generally recommended, as meeting today's requirements on the basis of error rates requires unacceptably large sample sizes. The demonstration of capability based on continuous characteristics using procedures 1–5 is always and absolutely preferred.

Definition: Measurement process and measurement system

→ AIAG Core Tool MSA 4th Edition


Terminology

Chapter I – Section A
Introduction, Purpose and Terminology


- **Measurement System** is the collection of instruments or gages, standards, operations, methods, fixtures, software, personnel, environment and assumptions used to quantify a unit of measure or fix assessment to the feature characteristic being measured; the complete process used to obtain measurements.

From these definitions it follows that a measurement process may be viewed as a manufacturing process that produces numbers (data) for its output. Viewing a measurement system this way is useful because it allows us to bring to bear all the concepts, philosophy, and tools that have already demonstrated their usefulness in the area of statistical process control.


Definition: Measurement process and measurement system




Classification of measurement errors




Taking measurement errors into account



ISO 14253 requirement



Taking measurement errors into account



(Quotes:)

- Capability is demonstrated through measurement and tests at the site of operation of the measurement or test equipment and through statistical analyses.
- This makes only sense for measurement and test equipment which (e.g. in the flow of production) performs a sufficiently large number of uniform, repetitive measurements or tests, and only ever applies to the checked characteristic.
- If the same measurement or test equipment is used to perform measurements or tests of different characteristics, capability must be demonstrated again for each new characteristic.
- Where measurement tasks change frequently (e.g. in development and testing areas), determination of measurement uncertainty is preferred to capability.
- Where conformance statements per ISO 14253 are required, determining measurement uncertainty is necessary instead of or in addition to demonstration of capability.
- If there are valid reasons why the methods described cannot be applied, the suitability of other methods should be explored ...

Impact of measurement process variation

$$\sigma^2_{\text{observed}} = \sigma^2_{\text{actual}} + \sigma^2_{\text{measuring system}}$$



**Observed
process variation**




**Actual
process variation**




**Variation of the
measuring system**

**Impact on process
capability!**


Impact of measurement process variation



Impact of measurement process variation




Impact of measurement process variation



- Procedure 1 – Measurement of standard/reference - C_g/C_{gk}
 - Prerequisite for procedures 2 to 5
 - Procedure 2 – Repeatability and reproducibility - %GRR
 - Influence of real parts and appraisers
 - Procedure 3 – Appraiser-independent systems - %GRR
 - Replaces procedure 2 for appraiser-independent systems
 - Procedure 4 – Linearity study
 - If not investigated by manufacturer/at calibration
 - Procedure 5 – Stability
 - Long-term assessment/monitoring
 - Procedure 6 – Discrete characteristics with continuous reference values
 - Determine “grey area” of uncertain decisions as “%GRR”
 - Procedure 7 – Discrete characteristics with and without cont. ref. values
 - Assessment using a κ -value (Fleiss' kappa)
- Standard methods for approval of variable measuring systems*


Methods





Flow chart

Measurement processes



- ➔ Assess resolution
- ➔ Perform capability analyses
- ➔ If capable: use measurement systems and monitor stability
- ➔ If not capable:
 - Optimize
 - Risk analysis
 - Conditional approval and re-qualification



Flow chart




Flow chart




Starting point of a measurement system analysis

- Purchase of a new measurement system
- New application of an existing measurement system
 - New products
 - New characteristics
 - New measurement strategies
 - ...
- Revision of a measurement system
 - Regular maintenance
 - Repair
 - Expansion/change of a system
 - ...
- Viewed as a study of a measurement “process” – whenever something might have changed about a process parameter/variable

Flow chart



Resolution of a display





Resolution: the smallest change in a measured characteristic that causes a noticeable change in the relevant display [VIM, 4.14]

Resolution of a display: the smallest difference between indicated values that can be meaningfully distinguished [VIM, 4.15]

2

Flow chart



Procedure 1 – Using a measurement standard

→ Objective

To demonstrate the capability of a measurement process (as a test process for a certain characteristic) in terms of the location and variation of measured values within the characteristic's tolerance region.

→ Requirements


- Product characteristics with a bilateral tolerance
- If there is a natural limit, this is used as a replacement (e.g. gap width, roughness, evenness ... USL is defined, $LSL^* = 0$)
- Calibrated measurement standard (reference part) available

→ Conducting the study

- The standard is measured 50 times (min. 25 times) under repeatability conditions


Procedure 1 – Process

- Documentation
- Data collection
- If T or T* (natural limit) is defined
 - Calculate capability indices
 - Assess capability indices ($C_g, C_{gk} \geq 1.33$)
- If T is not defined
 - Calculate critical limits USL_0/LSL_0
 - Define acceptance criterion for measured values



Procedure 1 – Data collection

- Typically 50 (min. 25) measurements
 - of a measurement standard
 - under repeatability conditions
- Defined measurement point on the standard
- Replace standard after each measurement (reinsert, reclamp, recontact)



Procedure 1 – Components of uncertainty

Bias

$$B_i = \bar{x}_g - x_m$$

Spread


$$6 s_g$$

Remember:

✓ Mean

$$\bar{x}_g = \frac{\sum x_i}{n}$$
$$s_g = \sqrt{\frac{\sum (\bar{x} - x_i)^2}{n-1}}$$

✓ Standard deviation



Procedure 1 – Calculating the indices

Bias

$$Bi = \bar{x}_g - x_m$$

Capability indices:

$$C_g = \frac{0,2 \cdot T}{6 \cdot s_g}$$

$$C_{gk} = \frac{0,1 \cdot T - |Bi|}{3 \cdot s_g}$$


Remember:

✓ Mean

$$\bar{x}_g = \frac{\sum x_i}{n}$$

$$s_g = \sqrt{\frac{\sum (\bar{x} - x_i)^2}{n-1}}$$


✓ Standard deviation



→ Measurement standard

Realization of the definition of a given **quantity, with stated quantity value and associated measurement uncertainty**, used as a reference [VIM, 5.1]





*Note 1: A “realization of the definition of a given quantity” can be provided by a **measuring system**, a **material measure**, or a reference material.*




Requirements for the standard

- Must enable an unambiguous result under repeatability conditions and be stable long-term
- Must have the same characteristic as the objects that the measuring equipment is later expected to measure
- Must be clearly marked as a standard, suitably calibrated, and included in the control of inspection, measurement and test equipment.
- The documented uncertainty U_{cal} of the standard should be significantly smaller than the specified tolerance T for the tested product characteristic
 - Ideal case $U_{cal} < 0.01\%T$
 - Minimum requirement $U_{cal} < 0.1\%T$
- If a corresponding object is not available, procedure 1 cannot be performed, and a suitable alternative method has to be found

Procedure 1 – Assessment with standard


Drawing Values			Collected Values			Statistics					
$x_{m+0.1 \times T}$	=	6.00800	$x_{max\ g}$	=	6.002	\bar{x}_g+3s_g	=	6.00388			
x_m	=	6.00200	$ B $	=	0.0011000	\bar{x}_g	=	6.00090			
$x_{m-0.1 \times T}$	=	5.99600	$x_{min\ g}$	=	5.999	\bar{x}_g-3s_g	=	5.99792			
$0.2 \times T$	=	0.01200	R_g	=	0.003	$6s_g$	=	0.00597			
T	=	0.060	n_{tot}	=	50	s_g	=	0.00099488			
Unit	=	mm									
Test for Bias						Test results : significant ($\alpha \leq 0,1\%$)					
Minimum reference figure for capable measuring system											
$C_g = \frac{0.2 \times T}{6 \times s_g}$			$= 1.61 \leq \mathbf{2.01} \leq 2.41$						$T_{min}(C_g)$	=	0.039701
$C_{gk} = \frac{0.1 \times T - \bar{x}_g - x_m }{3 \times s_g}$			$= 1.30 \leq \mathbf{1.64} \leq 1.98$						$T_{min}(C_{gk})$	=	0.050696
Resolution		%RES =	1.67%						$T_{min}(RES)$	=	0.020000
Measurement system capable (RES, C_g , C_{gk})											
BOSCH 2005 - MSA 3 (ANOVA) - Normal: Verfahren 1											

Procedure 1 – One-sided characteristics




“Acceptance criterion for measured values”

Takes into account Bias B_i and gauge variation s_g




Reduced “tolerances”,
similar to approach in ISO 14253



Procedure 1 – One-sided characteristics

- Imagine it this way: “The critical limit is offset by the bias plus 4 standard deviations from the specification limit”
- Standard for procedure 1 should be within $\pm 10\%$ of the specification limit
- Bias Bi must enter the calculation with correct sign (!)
- $4 s_g$ for $C_g/C_{gk} \geq 1.33$; $5 s_g$ for $C_g/C_{gk} \geq 1.67$; $6 s_g$ for $C_g/C_{gk} \geq 2.0$




$$LSL_0 = LSL + Bi + 4s_g$$

$$USL_0 = USL + Bi - 4s_g$$

where

$$Bi = \bar{x}_g - x_m$$

Reduced “tolerances”,
similar to approach in ISO 14253




Alternative method according to AIAG MSA

- AIAG MSA does not contain the procedure 1. Instead, it recommends testing systematic measurement errors $B_i = \bar{x} - x_m$ for significance (test for significant bias)
- Approach of the test for significant bias:
 - The bias in a procedure 1 is calculated from the 25 (50) measured values
 - Any further measurement would slightly change the bias
 - In other words, the present bias value is a random variable subject to random variation (confidence interval)
 - So a bias might show even for an ideal gauge
 - If the bias is close to zero, so that zero is within the confidence interval, then the bias is negligible
 - If the bias is too large, i.e. significantly different from zero, action must be taken



Alternative method according to AIAG MSA

- Advantages of the test for significant bias
 - Statistical significance test (1-sample t-test)
 - Checks one specific component of uncertainty
- Limits/weaknesses of the test for significant bias
 - A (minimal) bias is generally unavoidable
 - A significant bias only says that there is a demonstrable bias, but does not assess it relative to a requirement (e.g. tolerance)
 - Experience has shown that it leads to problems in practice:
 - High-quality standards/measurement systems: the smaller the system variation, the more significant the bias (“... the more the systematic error stands out against the small amount of noise”).
→ Criterion not satisfied, even though measurement error is very small
 - Low-quality standards/measurement systems: the converse case – the bias does not show up as significant
→ Criterion satisfied, even though error is unacceptably large
 - The more measurements are taken, the more significant the bias (“... the more the random variation averages out”)


Alternative method according to AIAG MSA




Flow chart




Procedure 4 – Linearity



Procedure 4 – Linearity



Procedure 4 – Linearity



Procedure 4 – Linearity

→ Objective

To demonstrate that there is a sufficiently linear relationship between the values of a physical quantity to be measured and the corresponding values determined by the measuring system (systematic measurement errors are within acceptable limits across the relevant range of measurement)

→ Requirements

Often checked by the manufacturer and then as part of regular calibration of the measuring system.

Must be demonstrated in individual cases, e.g.

- Adjustable gain
- Logarithmic scale
- Error limit related to full scale

Procedure 4 – Linearity

→ Conducting the study

Unlike the other study types, a wide variety of suggested methods can be found in the literature. These are mainly:

- Methods using explicit analysis of a mathematical linearity function (regression analysis)
 - Very complex and thus prone to errors
 - Not very intuitive and therefore difficult to evaluate in practice
- Methods based on a “band of variation” within which the results should lie
 - No linearity study in the strict sense
 - Easy standardized implementation


Procedure 4 – Linearity

Conducting the study :

Use several standards (min. 5),

- which are distributed in a suitable manner across the relevant measuring range (e.g. equidistantly in case of a linearly scaled range).
 - Perform procedure 1 for each of these standards
 - Calculate the corresponding indices C_g and C_{gk} .
-
- If only 2 standards are available, it is best for these to correspond to the limits of the tolerance range

Procedure 4 – Linearity




Select at least 5 standards across the relevant measurement range

Perform procedure 1 for each of them

Calculate C_g and C_{gk} as in procedure 1

Evaluate C_g and C_{gk} as in procedure 1
($C_g/C_{gk} \geq 1.33$)

Procedure 4 – Linearity using regression line



In the ideal case, the line of best fit has:

Intercept
Slope


$$a = 0$$

$$b = 1$$


Note: This method corresponds to the method in AIAG MSA and may be a customer requirement

Procedure 4 – Linearity using regression line

Measured values



Measurement errors




In the ideal case:

Intercept $a = 0$

Slope $b = 0$

Procedure 4 – Assessment per AIAG MSA

Measurement errors



The t-tests show:

The deviations from the ideal case are

- **significant (**)** for the slope b
- **highly significant (***)** for the intercept a

Test of slope	3.80822***
Test of intercept	3.43826**
BOSCH 2005 - MSA 3 (ARM) - Normal: Linearität	

In the ideal case:

Intercept $a = 0$

Slope $b = 0$

So the measurement system is unsuitable!

Does not correspond to practice!

Procedure 2 – Repeatability and reproducibility with appraiser influence

Objective

- To demonstrate the capability of a measurement process (as a test process for a defined characteristic) in terms of its variability, using measurements of standard production parts.

Requirements

- Appraiser influence cannot be excluded
- Production parts are available
- Parts should be within tolerance
- Measurements are repeatable

Procedure 2 – Repeatability and reproducibility with appraiser influence

Conducting the study

- Performed under operating conditions which correspond to the later operational conditions of the measuring equipment.
- Measure –
 - At least 10 series production parts that are randomly selected and repeatably measurable
 - In random sequence
 - Using at least 3 appraisers
 - Using at least 2 measurement runs
 - Under repeatability conditions and at defined measurement points.
- A new measurement series may only be begun once the previous run has been completed.

Procedure 2 – Repeatability and reproducibility with appraiser influence


→ Analysis

There are two analysis methods (models)

- ANOVA (ANalysis Of Variance)
 - Recommended method
 - Identifies 3 components of variation (see following slides)
 - Requires computer assistance in practice
- ARM (Average Range Method)
 - Was the previous standard
 - “Out of date and no longer recommended”
 - Identifies only 2 components of variation
 - Can be performed manually, but uses various approximations, estimates and correction factors (historical reasons)

Procedure 2 – Process

- Documentation
- Measurement series 1
3 appraisers measure 10 parts
in random order
- Measurement series 2
3 appraisers measure the 10 parts
again in random order
- Analysis
- Capability assessment




Procedure 2 – Repeatability and reproducibility with appraiser influence

→ The measurement results will generally ...

- ... vary about a mean for each part
(**repeatability**)
- ... have different means for each appraiser
(**reproducibility**)
- ... have different means per part and per appraiser
(**interaction**)

[shown for two parts in the graph]



Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A			Appraiser B			Appraiser C		
	1	2		1	2		1	2	
1	6,029	6,030		6,033	6,032		6,031	6,030	
2	6,019	6,020		6,020	6,019		6,020	6,020	
3	6,004	6,003		6,007	6,007		6,010	6,006	
4	5,982	5,982		5,985	5,986		5,984	5,984	
5	6,009	6,009		6,014	6,014		6,015	6,014	
6	5,971	5,972		5,973	5,972		5,975	5,974	
7	5,995	5,997		5,997	5,996		5,995	5,994	
8	6,014	6,018		6,019	6,015		6,016	6,015	
9	5,985	5,987		5,987	5,986		5,987	5,986	
10	6,024	6,028		6,029	6,025		6,026	6,025	

- Total variation is composed of
- Part-to-part variation
 - Variation between appraisers
 - Interaction between appraiser and part
 - Measuring equipment variation (“the rest”)

Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A			Appraiser B			Appraiser C		\bar{x} of part, all appraisers
	1	2		1	2		1	2	
1	6,029	6,030		6,033	6,032		6,031	6,030	6,0308
2	6,019	6,020		6,020	6,019		6,020	6,020	6,0197
3	6,004	6,003		6,007	6,007		6,010	6,006	6,0062
4	5,982	5,982		5,985	5,986		5,984	5,984	5,9838
5	6,009	6,009		6,014	6,014		6,015	6,014	6,0125
6	5,971	5,972		5,973	5,972		5,975	5,974	5,9728
7	5,995	5,997		5,997	5,996		5,995	5,994	5,9957
8	6,014	6,018		6,019	6,015		6,016	6,015	6,0162
9	5,985	5,987		5,987	5,986		5,987	5,986	5,9863
10	6,024	6,028		6,029	6,025		6,026	6,025	6,0262

Variance of means \bar{x}
of all parts

$s^2_{PV} = 0,000381231$

→ Total variation is composed of

- Part-to-part variation
- Variation between appraisers
- Interaction between appraiser and part
- Measuring equipment variation (“the rest”)

⇒ PV Part Variation

Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A			Appraiser B			Appraiser C		\bar{x} of part all appraisers
	1	2		1	2		1	2	
1	6,029	6,030		6,033	6,032		6,031	6,030	6,0308
2	6,019	6,020		6,020	6,019		6,020	6,020	6,0197
3	6,004	6,003		6,007	6,007		6,010	6,006	6,0062
4	5,982	5,982		5,985	5,986		5,984	5,984	5,9838
5	6,009	6,009		6,014	6,014		6,015	6,014	6,0125
6	5,971	5,972		5,973	5,972		5,975	5,974	5,9728
7	5,995	5,997		5,997	5,996		5,995	5,994	5,9957
8	6,014	6,018		6,019	6,015		6,016	6,015	6,0162
9	5,985	5,987		5,987	5,986		5,987	5,986	5,9863
10	6,024	6,028		6,029	6,025		6,026	6,025	6,0262
	6,0039			6,0058			6,0054		
				\bar{x} of each appraiser					
	Variance of appraisers			$s^2_{AV} = 9,86E-07$					

- Part-to-part variation
- Variation between appraisers
- Interaction between appraiser and part
- Measuring equipment variation (“the rest”)

⇒ **PV Part Variation**

⇒ **AV Appraiser Variation**

Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A		\bar{x} of part at appraiser A	Appraiser B		\bar{x} of part at appraiser B	Appraiser C		\bar{x} of part at appraiser C	\bar{x} of part of all appraisers	Variance of means \bar{x} of each part
	1	2		1	2		1	2			
1	6,029	6,030	6,0295	6,033	6,032	6,0325	6,031	6,030	6,0305	6,0309	$s^2_{IA1}= 2,33333E-06$
2	6,019	6,020	6,0195	6,020	6,019	6,0195	6,020	6,020	6,0200	6,0196	$s^2_{IA2}= 8,33333E-08$
3	6,004	6,003	6,0035	6,007	6,007	6,0070	6,010	6,006	6,0080	6,0059	$s^2_{IA3}= 5,58333E-06$
4	5,982	5,982	5,9820	5,985	5,986	5,9855	5,984	5,984	5,9840	5,9838	$s^2_{IA4}= 3,08333E-06$
5	6,009	6,009	6,0090	6,014	6,014	6,0140	6,015	6,014	6,0145	6,0123	$s^2_{IA5}= 9,25E-06$
6	5,971	5,972	5,9715	5,973	5,972	5,9725	5,975	5,974	5,9745	5,9726	$s^2_{IA6}= 2,33333E-06$
7	5,995	5,997	5,9960	5,997	5,996	5,9965	5,995	5,994	5,9945	5,9958	$s^2_{IA7}= 1,08333E-06$
8	6,014	6,018	6,0160	6,019	6,015	6,0170	6,016	6,015	6,0155	6,0163	$s^2_{IA8}= 5,83333E-07$
9	5,985	5,987	5,9860	5,987	5,986	5,9865	5,987	5,986	5,9865	5,9863	$s^2_{IA9}= 8,33333E-08$
10	6,024	6,028	6,0260	6,029	6,025	6,0270	6,026	6,025	6,0255	6,0263	$s^2_{IA10}= 5,83333E-07$
6,0039			6,0058			6,0054					
			\bar{x} of each appraiser								
									Minus PV and AV		
									$\Rightarrow s^2_{IA}$		

→ Total variation is composed of

- Part-to-part variation
- Variation between appraisers
- Interaction between appraiser and part
- Measuring equipment variation (“the rest”)

⇒ **PV** Part Variation

⇒ **AV** Appraiser Variation

⇒ **IA** Interaction

Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A		\bar{x} of part at appraiser A	Appraiser B		\bar{x} of part at appraiser B	Appraiser C		\bar{x} of part at appraiser C	\bar{x} of part of all appraisers
	1	2		1	2		1	2		
1	6,029	6,030	6,0295	6,033	6,032	6,0325	6,031	6,030	6,0305	6,0309
2	6,019	6,020	6,0195	6,020	6,019	6,0195	6,020	6,020	6,0200	6,0196
3	6,004	6,003	6,0035	6,007	6,007	6,0070	6,010	6,006	6,0080	6,0059
4	5,982	5,982	5,9820	5,985	5,986	5,9855	5,984	5,984	5,9840	5,9838
5	6,009	6,009	6,0090	6,014	6,014	6,0140	6,015	6,014	6,0145	6,0123
6	5,971	5,972	5,9715	5,973	5,972	5,9725	5,975	5,974	5,9745	5,9726
7	5,995	5,997	5,9960	5,997	5,996	5,9965	5,995	5,994	5,9945	5,9958
8	6,014	6,018	6,0160	6,019	6,015	6,0170	6,016	6,015	6,0155	6,0163
9	5,985	5,987	5,9860	5,987	5,986	5,9865	5,987	5,986	5,9865	5,9863
10	6,024	6,028	6,0260	6,029	6,025	6,0270	6,026	6,025	6,0255	6,0263
6,0039			6,0058			6,0054				
			\bar{x} of each appraiser							
Variance of all measurements			$s^2_{EV} = 0,000352$			Minus variation from PV, AV and IA				

- Part-to-part variation
- Variation between appraisers
- Interaction between appraiser and part
- Measuring equipment variation ("the rest")

⇒ **PV Part Variation**

⇒ **AV Appraiser Variation**

⇒ **IA Interaction**

⇒ **EV Equipment Variation**

Procedure 2 – ANOVA calculation of statistics

Part	Appraiser A		\bar{x} of part at appraiser A	Appraiser B		\bar{x} of part at appraiser B	Appraiser C		\bar{x} of part at appraiser C	\bar{x} of part all appraisers
	1	2		1	2		1	2		
1	6,029	6,030	6,0295	6,033	6,032	6,0325	6,031	6,030	6,0305	6,0309
2	6,019	6,020	6,0195	6,020	6,019	6,0195	6,020	6,020	6,0200	6,0196
3	6,004	6,003	6,0035	6,007	6,007	6,0070	6,010	6,006	6,0080	6,0059
4	5,982	5,982	5,9820	5,985	5,986	5,9855	5,984	5,984	5,9840	5,9838
5	6,009	6,009	6,0090	6,014	6,014	6,0140	6,015	6,014	6,0145	6,0123
6	5,971	5,972	5,9715	5,973	5,972	5,9725	5,975	5,974	5,9745	5,9726
7	5,995	5,997	5,9960	5,997	5,996	5,9965	5,995	5,994	5,9945	5,9958
8	6,014	6,018	6,0160	6,019	6,015	6,0170	6,016	6,015	6,0155	6,0163
9	5,985	5,987	5,9860	5,987	5,986	5,9865	5,987	5,986	5,9865	5,9863
10	6,024	6,028	6,0260	6,029	6,025	6,0270	6,026	6,025	6,0255	6,0263
	6,0039			6,0058			6,0054			
				\bar{x} of each appraiser						

→ GRR, the variation of the measurement system, is composed of

- AV = $\hat{\sigma}_{AV}$ Appraiser Variation
 - IA = $\hat{\sigma}_{IA}$ Interaction
 - EV = $\hat{\sigma}_{EV}$ Equipment Variation
 - \Rightarrow GRR = $\hat{\sigma}_{GRR}$ Gage Repeatability & Reproducibility
- $GRR = \sqrt{EV^2 + AV^2 + IA^2}$

Procedure 2 – ANOVA calculation of statistics

	Variance	Standard dev.			
Repeatability	0.0000023556	0.0015348	$0.0012799 \leq 0.0015348 \leq 0.0019174$	%EV = 15.35%	
Reproducibility	0.00000086806	0.00093169	$0.00035980 \leq 0.00093169 \leq 0.0062290$	%AV = 9.32%	
Interaction	---			%IA = ---	
Repeatability & Reproducib	0.0000032236	0.0017954 ¹⁵	$0.0015827 \leq 0.0017954 \leq 0.0064169$	%GRR = 17.95%	
Tolerance = T = 0.060 Confidence interval = 1-α = 95.000%					
Resolution	=	%RES	= 1.67%		
Repeatability & Reproducibility	=	%GRR	= 17.95%		
Part Variation	=	%PV	= 195.15%		
number of distinct categories	=	ndc	= 15		
Measurement system marginally capable (RES,%GRR)					
BOSCH 2005 - MSA 3 (ANOVA) - Normal Verfahren 2					
		T _{min} (%GRR)	0.10773	T _{min} (%GRR)	0.035909

→ GRR

- AV = $\hat{\sigma}_{AV}$
- IA = $\hat{\sigma}_{IA}$
- EV = $\hat{\sigma}_{EV}$
- ⇒ GRR = $\hat{\sigma}_{GRR}$

Appraiser Variation

Interaction


Equipment Variation

Gage Repeatability & Reproducibility

$$GRR = \sqrt{EV^2 + AV^2 + IA^2}$$

Procedure 2 – Compare GRR to tolerance

- GRR corresponds to one standard deviation s
- Spread is typically expressed as six standard deviations (cf. procedure 1):
Spread = $6 s = 6 \times \text{GRR}$
- The tolerance is used as a reference value




Procedure 2 – Requirements for %GRR

→ Requirements:

- $\%GRR \leq 10\%$ capable
- $10\% < \%GRR \leq 30\%$ conditionally capable
- $\%GRR > 30\%$ not capable

Repeatability & Reproducibility

$$= \%GRR = 6 \times \frac{GRR \times 100\%}{T} = 15.43\%$$




Procedure 2 – Report

Documentation


Run chart of deviations

Measurement results

Statistics and assessment




→ Run chart of deviations



- Deviation of individual measurement from the mean of all measurements for the relevant part
- Graphical representation of the variation statistics EV, AV und IA










Procedure 2 – Report



- Deviation of individual measurement from the mean of all measurements for the relevant part
- Graphical representation of the variation statistics EV, AV und IA


Procedure 2 – Report

→ Statistics


	Variance	Standard dev.		
Repeatability	0.0000023556	0.0015348	$0.0012799 \leq \mathbf{0.0015348} \leq 0.0019174$	%EV = 15.35% 
Reproducibility	0.00000086806	0.00093169	$0.00035980 \leq \mathbf{0.00093169} \leq 0.0062290$	%AV = 9.32% 
Interaction	---			%IA = --- 
Repeatability & Reproducib	0.0000032236	0.0017954 ¹⁵	$0.0015827 \leq \mathbf{0.0017954} \leq 0.0064169$	%GRR = 17.95% 
Tolerance = T = 0.060 Confidence interval = 1-α = 95.000%				
Resolution	=	%RES	= 1.67%	
Repeatability & Reproducibility	=	%GRR	= 17.95%	
Part Variation	=	%PV	= 195.15%	
number of distinct categories	=	ndc	= 15	
Measurement system marginally capable (RES,%GRR)				
Bosch Heft 10 (2003)/MSA 3 (ANOVA) - Normal: Verfahren 2				
		$T_{min} (\%GRR)$	0.10773	$T_{min} (\%GRR)$ 0.035909

Procedure 2 – Number of Distinct Categories ndc


→ Requirement: $ndc \geq 5$



Minimum requirement for SPC



Flow chart



Procedure 3 – Repeatability and reproducibility without appraiser influence

→ Objective

To demonstrate the capability of a measurement process (as a test process for a defined characteristic) in terms of its variability, using measurements of production parts, without appraiser influence.

→ Requirements

Before conducting procedure 3, a careful check has to be performed to verify that appraiser influence on measured values can be excluded.

This being a special case of procedure 2, the same requirements apply.

Procedure 3 – Repeatability and reproducibility without appraiser influence

→ Conducting the study

Performed under operating conditions which correspond to the later operational conditions of the measuring equipment.

Measure –


- At least 25 series production parts that are randomly selected and repeatably measurable
- In random sequence
- Using at least 2 measurement series
- Under repeatability conditions and at defined measurement points.

→ Analysis

- Per procedure 2 using ANOVA
- ARM analysis “out of date and no longer recommended”

Procedure 3 – Process

- Documentation
- Measurement series 1
Measure 25 parts in random order
- Measurement series 2
→ Measure the 25 parts again in random order
- Analysis
- Capability assessment



Procedure 3 – ANOVA calculation of statistics

Appraiser A			Appraiser B			Appraiser C				
n	$X_{A;1}$	$X_{A;2}$	$\bar{X}_{g j}$	$X_{B;1}$	$X_{B;2}$	$\bar{X}_{g j}$	$X_{C;1}$	$X_{C;2}$	$\bar{X}_{g j}$	$\bar{X}_{g n}$
1	6,029	6,030	6,0295	6,033	6,032	6,0325	6,031	6,030	6,0305	6,03083
2	6,019	6,020	6,0195	6,023	6,019	6,021	6,022	6,020	6,0200	6,01967
3	6,004	6,003	6,0035	6,007	6,007	6,0070	6,010	6,006	6,0080	6,00617
4	5,982	5,982	5,9820	5,985	5,986	5,9855	5,984	5,984	5,9840	5,98383
5	6,009	6,009	6,0090	6,014	6,014	6,0140	6,015	6,014	6,0145	6,01250
6	5,971	5,972	5,9715	5,973	5,972	5,9725	5,975	5,974	5,9745	5,97283
7	5,995	5,997	5,9960	5,997	5,996	5,9965	5,995	5,994	5,9945	5,99567
8	6,014	6,018	6,0160	6,019	6,015	6,0170	6,016	6,015	6,0155	6,01617
9	5,985	5,987	5,9860	5,987	5,986	5,9865	5,987	5,986	5,9865	5,98633
10	6,024	6,028	6,0260	6,029	6,025	6,0270	6,026	6,025	6,0255	6,02617

→ Total variation is composed of

- Part-to-part variation
- Variation between appraisers
- Interaction between appraiser and part
- Measuring equipment variation (“the rest”)

25

⇒PV Part Variation

⇒~~AV Appraiser Variation~~

⇒~~IA Interaction~~

⇒EV Equipment Variation

Procedure 3 – Report

Documentation



Run chart of individual values

Measurement results

Run chart of ranges

Statistics and assessment


BOSCH		Measurement System Analysis Type-3 Study		Sheet: 1 / 1	
Division	:MSE3	Operating sequence	:Mating corpus/needle	Char.Descrip.	:Corpus diameter
Group/Department	:MOE7	Mach.Descrip.	:PAKO 9	Char.No.	:1
Workshop/sector	:W450	Mach.No.	:1003521	Nominal Value	:6,000
Product	:Injector	Test Location	:JML0563W001	Lower Allowance	:0,030
Part	:Hole type nozzle	Gage Descrip.	:JML0563W003	Upper Allowance	:0,030
TP number	:0 433 171 914	Gage No.	:6702779470004	Tolerance	:0,060
Amendment status	:20050819	Gage Manu.	:BaP	Unit	:mm
Resolution	:0,001				
Comment					
Master Descrip.		Master No.		Standard/reference	



Part no.	0 433 171 914	Part descr.	Hole type nozzle
Char.No.	1	Char.Descrip.	Corpus diameter
Repeatability	0.00002400	Standard dev.	0.0014567
Repeatability & Reproducibility	0.00002400	0.0014567	0.0014567
Tolerance	T = 0.060	Confidence interval	± 14.70%
Resolution	%RES = 1.87%		
Repeatability & Reproducibility	%R&R = 14.70%		
Part Variation	%PV = 177.01%		
Number of distinct categories	ndc = 17		
Measurement system marginally capable (RES, %R&R)			
BOSCH 2005 - MSA 3 (ANOVA) - Normal Verfahren 3			
T _{95%/100%} = 0.000181 T _{95%/90%} = 0.000194			

Test Plan Development : 18.07.2007 Test Plan Developer: BaP/MFT7.62 Test Begin : 18.03.2010 Operator name : W123John Q. Public
 Department : 8.80 / 91216 MNW_GC_V3_B.def Name : Robert Bosch GmbH Date : Signature :
 17.12.2010 C:\CRATCH\isolara-Reports\H10E-pp17-Report-qs-STAT-V3.DFG

Procedure 3 – Report



Procedure 3 – Calculate statistics



n	X _{A,1}	X _{A,2}	\bar{x}_{gj}	s _{gj}				
1	6,029	6,030	6,0295	0,0007				
2	6,019	6,020	6,0195	0,0007				
3	6,004	6,003	6,0035	0,0007				
4	5,982	5,982	5,9820	0,0000				
5	6,009	6,009	6,0090	0,0000				
6	5,971			Variance	Standard dev.			
7	5,995	Repeatability		0.0000021600	0.0014697	0.0011526 ≤ 0.0014697 ≤ 0.0020288	%EV = 14.70%	
8	6,014	Repeatability & Reproducib		0.0000021600	0.0014697 ¹⁵	0.0011526 ≤ 0.0014697 ≤ 0.0020288	%GRR = 14.70%	
9	5,985							
10	6,024	Tolerance = T = 0.060		Confidence interval = 1-α = 95.000%				
11	6,033							
12	6,020	Resolution = %RES = 1.67%						
13	6,007							
14	5,985	Repeatability & Reproducibility = %GRR = 14.70%						
15	6,014							
16	5,973	Part Variation = %PV = 177.01%						
17	5,997							
18	6,019	number of distinct categories = ndc = 17						
19	5,987							
20	6,029							
21	6,017	Measurement system marginally capable (RES,%GRR) 😞						
22	6,003							
23	6,009	Bosch Heft 10 (2003)/MSA 3 (ANOVA) - Normal: Verfahren 3						
24	5,987					T _{min} (%GRR) 0.088181	T _{min} (%GRR) 0.029394	
25	6,006	6,003	6,0045	0,0021				

Measurement results


Statistics



Flow chart



Procedure 5 – Stability



Procedure 5 – Stability

→ Objective

To demonstrate consistent accuracy of results by monitoring long-term performance of a measurement process and conducting a corresponding assessment of the stability of the measuring system (similar to an \bar{x} -s control chart)

→ Requirements

- Stable long-term performance cannot be safely assumed
- A reference part (measurement standard, or a stable, possibly modified production part) is available (see also requirements for the measurement standard used in procedure 1)


Procedure 5 – Stability

→ Conducting the study


- At least three measurements ($n \geq 3$) of the reference part (stability part) are taken at regular intervals (inspection intervals, sampling intervals), as defined for the specific process.
- Document the measurement results in the data table of the stability chart.
- Calculate mean and standard deviation for each sample.
- Plot the values in their time sequence on the \bar{x}/s -chart.
- The \bar{x} -chart can use the actual values or the deviations from the reference value x_m , i.e. the differences between the measurement results and the reference value (residuals).

Procedure 5 – Stability

→ Conducting the study



Procedure 5 – Stability chart



→ Calculations as for regular control charts

Procedure 5 – Stability chart

Control limits for stability charts

	Lower control limit (LCL)	Upper control limit (UCL)
\bar{X} -chart (mean values):	$LCL = x_m - u_p \cdot \frac{s}{\sqrt{n}}$	$UCL = x_m + u_p \cdot \frac{s}{\sqrt{n}}$
s-chart (standard deviations):	$LCL_s = B'_{Eun} \cdot s$	$UCL_s = B'_{Eob} \cdot s$
Individual value chart:	$LCL = x_m - E'_E \cdot s$	$UCL = x_m + E'_E \cdot s$

For x_m the following values can be used:

- the reference value of the reference part (stability part) or
- the mean value of a previous/provisional test run (see [AIAG MSA], chapter 3, paragraph B).

For s the following values can be used:

- 2.5% of the characteristic tolerance T ($=T/40$) or
- the standard deviation of a previous/provisional test run (see [AIAG MSA], chapter 3, paragraph B).
- the standard deviation from procedure 1 (not recommended because of short-term examination).

The sample size is used for n , i.e. the number of measurements per sample.

u_p , B'_{Eun} , B'_{Eob} and E'_E are used corresponding to the sample size n according to the following table for confidence level 99.73%. For individual value charts, it must be decided how many measured values are combined in one group of the size n (pseudo-sample). $n = 3$ is well-established.

n	u_p	B'_{Eun}	B'_{Eob}	E'_E
3	3.000	0.037	2.571	3.320
4	3.000	0.100	2.283	3.399
5	3.000	0.163	2.110	3.460

Procedure 5 – Inspection interval

- No fixed rule, depends on the measurement process and its behavior over time
- General principle: begin with short intervals, then lengthen
- Examples of typical criteria for using short intervals:
 - Unstable measurement process
 - Capability indices are close to the limit
 - Characteristic is critical to function or to correct process operation
 - New measurement / test methods
 - No empirical values available
 - High statistical confidence required
 - Timely corrective action must be assured in the event of errors

Procedure 5 – Inspection intervals are ...

- ... appropriate, if
 - All averages are within the control limits
 - There are visible random changes from value to value
 - ⇒ *One control measurement per shift is usually enough*
 - ⇒ *If there is long-term stability, the interval may be lengthened*
- ... too short, if there are no or only minimal changes from value to value
 - ⇒ *However, one control measurement per shift is a must!*
- ... too long, if there are values beyond the control limits

Special case: If the equipment is recalibrated or adjusted before each measurement, stability monitoring is not required



Procedure 5 – Stability criteria

- Stable measurement process
 - All values within the control limits
 - Random variation without special causes

- Unstable measurement process
 - Values beyond the control limits
 - Large random variation over time
 - Signs of special causes
 - Run
 - Trend
 - Middle Third

- If the measurement process is unstable:
 - Identify causes; risk analysis: improvement and re-approval


Flow chart



Repeat demonstration of capability


- No defined requirements as for control of inspection, measurement and test equipment!
- “During application in production, the capability of the measurement process must be ensured at all times (preferably using procedure 5).”
- Examples of criteria for re-approval:
 - Significant changes in the stability chart after an intervention
 - Recommissioning after maintenance or repair work etc.
 - Technical changes, significant parameter changes
 - Changes in conditions, environment, staff etc.
 - Before/after relocation
 - Suspected equipment errors
 - ...

Methods





Flow chart – Test processes

- Assess characteristic and define study type
- Perform capability analyses
- If capable: use
- If not capable:
 - Optimize
 - Risk analysis
 - Conditional approval and re-qualification




Flow chart



Procedure 6 – Discretized continuous characteristics

- We're looking for the average width of the grey area near USL and LSL



Procedure 6 – Discretized continuous characteristics

→ Objective

To demonstrate the capability of a test process in terms of its ability to deliver unambiguous decisions when testing discretized characteristics.

→ Requirements

- A reference lot made up of 50 reference parts from production (normal production parts), whose discrete characteristic values are determined and documented prior to the start of test.
- The measurement uncertainty U for the measured values must be known.
- The characteristic values of the reference parts should cover a range beginning just below $LSL - U$ and ending just above $USL + U$. The measurement result for each reference part is documented.

Procedure 6 – Discretized continuous characteristics

→ Conducting the study

“Signal detection” method

- For each gaged characteristic look for ...
- ... 50 parts spread out across the tolerance interval (+/- U).
- Determine a reference value for each part (and for each checked characteristic in case of gages that check several characteristics) in the gage room.
- Let the parts be checked ...
- ... by 2 appraisers ...
- ... 2 times each ...
- ... in random order.
- Enter the results in a table.

n	Ref. 1	X A1	X A2	X R1	X R2	
1	3,6320			+	+	⊖
2	3,6490					⊖
3	3,5870	+	+	+	+	⊖
4	3,5520	+				⊖
5	3,6210	+	+	+	+	⊖
6	3,6450					⊖
7	3,6520					⊖
8	3,5990	+	+	+	+	⊖
9	3,6340				+	⊖
10	3,6250	+	+	+	+	⊖
11	3,5720	+	+	+	+	⊖
12	3,5520	+				⊖
13	3,5950	+	+	+	+	⊖
14	3,5610	+	+	+	+	⊖
15	3,6170	+	+	+	+	⊖
16	3,5850	+	+	+	+	⊖
17	3,5310					⊖
18	3,5820	+	+	+	+	⊖
19	3,5440					⊖
20	3,5740	+	+	+	+	⊖
21	3,5950	+	+	+	+	⊖
22	3,6420					⊖
23	3,6210	+	+	+	+	⊖
24	3,5650	+				⊖
25	3,5930	+	+	+	+	⊖
26	3,6220	+	+	+	+	⊖
27	3,6320			+	+	⊖
28	3,6640					⊖
29	3,5480					⊖
30	3,6520					⊖
31	3,5860	+	+	+	+	⊖
32	3,6410					⊖
33	3,6140	+	+	+	+	⊖
34	3,6000	+	+	+	+	⊖
35	3,5910	+	+	+	+	⊖
36	3,6320			+	+	⊖
37	3,5700	+	+	+	+	⊖
38	3,6030	+	+	+	+	⊖
39	3,5780	+	+	+	+	⊖
40	3,5970	+	+	+	+	⊖
41	3,5870	+	+	+	+	⊖
42	3,6140	+	+	+	+	⊖
43	3,6130	+	+	+	+	⊖
44	3,5920	+	+	+	+	⊖
45	3,5600	+				⊖
46	3,6260	+	+	+	+	⊖
47	3,6320					⊖
48	3,5730	+	+	+	+	⊖
49	3,5590	+	+			⊖
50	3,6090	+	+	+	+	⊖


Procedure 6 – Discretized continuous characteristics

n	Ref. 1	X A1	X A2	X B1	X B2	
28	3,6640					
7	3,6520					
30	3,6520					
2	3,6490					
6	3,6450					
22	3,6420					
32	3,6410					
9	3,6340					
27	3,6320					
36	3,6320					
1	3,6320					
47	3,6320					
46	3,6260					
10	3,6250					
26	3,6220					
23	3,6210					
5	3,6210					
15	3,6170					
33	3,6140					
42	3,6140					
43	3,6130					
50	3,6090					
38	3,6030					
34	3,6000					
8	3,5990					
40	3,5970					
13	3,5950					
21	3,5950					
25	3,5930					
44	3,5920					
35	3,5910					
41	3,5870					
3	3,5870					
31	3,5860					
16	3,5850					
18	3,5820					
39	3,5780					
20	3,5740					
48	3,5730					
11	3,5720					
37	3,5700					
24	3,5650					
14	3,5610					
45	3,5600					
49	3,5590					
4	3,5520					
12	3,5520					
29	3,5460					
19	3,5440					
17	3,5310					

Sort the results
in ascending order
according to the
reference value

n	Ref. 1	X A1	X A2	X B1	X B2	
1	3,6320					
2	3,6490					
3	3,5870					
4	3,5520					
5	3,6210					
6	3,6450					
7	3,6520					
8	3,5990					
9	3,6340					
10	3,6250					
11	3,5720					
12	3,5520					
13	3,5950					
14	3,5610					
15	3,6170					
16	3,5850					
17	3,5310					
18	3,5820					
19	3,5440					
20	3,5740					
21	3,5950					
22	3,6420					
23	3,6210					
24	3,5650					
25	3,5930					
26	3,6220					
27	3,6320					
28	3,6640					
29	3,5460					
30	3,6520					
31	3,5860					
32	3,6410					
33	3,6140					
34	3,6000					
35	3,5910					
36	3,6320					
37	3,5700					
38	3,6030					
39	3,5780					
40	3,5970					
41	3,5870					
42	3,6140					
43	3,6130					
44	3,5920					
45	3,5600					
46	3,6260					
47	3,6320					
48	3,5730					
49	3,5590					
50	3,6090					

Procedure 6 – Discretized continuous characteristics



$$\%GRR = \frac{\bar{d}}{T} \times 100\%$$

$$\bar{d} = \frac{d_{USL} + d_{LSL}}{2}$$

Assessment as per procedure 2:


up to 10% capable

up to 30%
conditionally
capable

over 30% not capable



Procedure 6 – Discretized continuous characteristics

BOSCH		Measurement System Analysis Discrete characteristics		Shee: 1 / 1
Division	: MSE3	Operating sequen	: Schleifen Innendurchmess	Char. Descr.
Group/Department	: MOE7	Mach. Descr.	: BOKO 3	: Innendurchm.
Workshop/sector	: W450	Mach. No.	: 1003954	Char. No.
Product	: Düse	Test Location	: JML0752W001	Nominal Value
Part	: Nadel	Gage Descr.	: LG_4H7N1	Lower Allowance
TP number	: 0 433 392 425	Gage No.	: 67027025840013	Upper Allowance
Amendment status	: 20080725	Gage Manu.	: BaP	Tolerance
		Resolution	: 0.002	Unit
Comment				
Comment				
Master Descr.		Master No.		Standard reference
n	Ref. 1	XA1	XA2	XB1
1	3.6320			
2	3.6460			
3	3.5870			
4	3.6520			
5	3.6210			
6	3.6450			
7	3.6520			
8	3.5990			
9	3.6340			
10	3.6250			
11	3.5720			
12	3.6520			
13	3.5860			
14	3.5810			
15	3.6110			
16	3.5850			
17	3.5310			
18	3.5220			
19	3.5440			
20	3.5740			
21	3.5950			
22	3.6420			
23	3.6210			
24	3.6550			
25	3.6000			
26	3.6220			
27	3.6320			
28	3.6440			
29	3.5460			
30	3.6520			
31	3.5980			
32	3.6410			
33	3.6140			
34	3.6000			
35	3.5910			
36	3.6320			
37	3.5700			
38	3.6030			
39	3.5780			
40	3.5970			
41	3.5870			
42	3.6140			
43	3.6130			
44	3.5620			
45	3.6000			
46	3.6260			
47	3.6320			
48	3.5730			
49	3.5590			
50	3.6090			
Test Plan Development	: 21.11.2008	Test Plan	: BaP/MT7.41	
Date		Test Begin	: 18.03.2010	Operator
Department		Name		: W123Austermann
29.06.2010		8.80 / 91216 GC_Alt_B.der	Robert Bosch GmbH	Signature



No. of Non-conformancies	n ↔	12
GRR	0.020000	
%GRR	26.67%	0 10 30
Measurement system marginally capable (GRR) 😞		
Bosch Heft 10 (2003)/MSA 3 (ANOVA) - Normal: attributiv		
%GRR	26.67%	0 10 30
Measurement system marginally capable (GRR) 😞		
Bosch Heft 10 (2003)/MSA 3 (ANOVA) - Normal: attributiv		

Flow chart



Procedure 7 – Discrete characteristics

→ Objective

To assess the capability of a test process in terms of its ability to deliver unambiguous decisions when testing discrete or discretized continuous characteristics.

→ Requirements

Clarify requirements for

- **Reference parts with continuous characteristics**

Measurable characteristics subject to (simplified) OK/NOK test

- **Reference parts with discrete characteristics**

Characteristics are not measurable, e.g. subjective visual inspection

- **Reference lot (master)**

Lot size, composition, identifiability

Procedure 7 – Discrete characteristics

- Requirements for
Reference parts with continuous characteristics
 - Per procedure 6
- Requirements for
Reference parts with discrete characteristics
 - Provide reference standards (boundary samples catalog)
 - Assign to categories (OK/NOK)
 - More categories may be possible (grades; scrap/good/rework)
- Requirements for
Reference lot (master)
 - 100–200 parts are recommended, per AIAG MSA at least 50
 - All relevant properties must be represented in typical proportions
 - All parts are uniquely identifiable (but not visible to the appraiser!)

Procedure 7 – Discrete characteristics

- Conducting the study
 - As in procedure 6 test and categorize the objects in random order under normal operating conditions
 - If appraiser influence is expected: use at least three appraisers and two test runs each
 - If appraiser influence is not expected: use at least six test runs
 - Use a random inspection order, and change it for each run

Procedure 7 – Discrete characteristics

→ Analysis

- Assess pairwise agreement of results, using the Kappa κ statistic

$$\kappa = \frac{\text{Observed non-random agreements}}{\text{Possible non-random agreements}}$$

Calculation details are presented in Appendix G.

The analysis comprises the following comparisons and the calculation of the corresponding statistic κ :

- Within appraisers: compare all test runs of each appraiser without checking against the reference (repeatability).
- Between appraisers: compare all test runs of all appraisers without checking against the reference (reproducibility).
 - Compare all test runs of each appraiser against the reference.
 - Compare all test runs of all appraisers against the reference.

Deviating from AIAG MSA, the analysis is performed using Fleiss' kappa statistics [Fleiss], which is more generally applicable. If the analysis according to AIAG MSA using Cohen's kappa statistics is explicitly requested (e.g. due to customer requirements), then proceed according to AIAG MSA.

Procedure 7 – Discrete characteristics

→ Capability assessment

Capability is assessed based on the κ statistic (“Kappa”):

- $\kappa \geq 0.9$: test process capable
- $0.9 > \kappa \geq 0.7$: test process conditionally capable
- $\kappa < 0.7$: test process not capable (unsuitable)
- Use the minimum of all the κ -values for the overall assessment.

1

© Robert Bosch GmbH 2010. All rights reserved, also regarding any disposal, exploitation, reproduction, editing, distribution, as well as in the event of applications for industrial property rights.

Record No. 9911015, Sheet 2 of 2


Test Object No.	Reference Value (continuous)	Reference Value (discrete or discretized)	Appraiser ID – Trial No.											
			Mayer						Huber					
			A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3			
1	n/a	1	1	1	1	1	1	1	1	1	1			
2	n/a	1	1	1	1	1	1	1	1	1	1			
3	n/a	0	0	0	0	0	0	0	0	0	0			
4	n/a	0	0	0	0	0	0	0	0	0	0			
5	n/a	0	0	0	0	0	0	0	0	0	0			
6	n/a	1	1	1	0	1	1	0	1	0	0			
7	n/a	1	1	1	1	1	1	1	1	0	1			
8	n/a	1	1	1	1	1	1	1	1	1	1			
9	n/a	0	0	0	0	0	0	0	0	0	0			
10	n/a	1	1	1	1	1	1	1	1	1	1			
11	n/a	1	1	1	1	1	1	1	1	1	1			
12	n/a	0	0	0	0	0	0	0	0	1	0			
13	n/a	1	1	1	1	1	1	1	1	1	1			
14	n/a	1	1	1	0	1	1	1	1	1	0			
15	n/a	1	1	1	1	1	1	1	1	1	1			
16	n/a	1	1	1	1	1	1	1	1	1	1			
17	n/a	1	1	1	1	1	1	1	1	1	1			
18	n/a	1	1	1	1	1	1	1	1	1	1			
19	n/a	1	1	1	1	1	1	1	1	1	1			
20	n/a	1	1	1	1	1	1	1	1	1	1			
21	n/a	1	1	1	0	1	0	1	0	1	0			
22	n/a	0	0	0	1	0	1	0	1	1	0			
23	n/a	1	1	1	1	1	1	1	1	1	1			
24	n/a	1	1	1	1	1	1	1	1	1	1			
25	n/a	0	0	0	0	0	0	0	0	0	0			
26	n/a	0	0	1	0	0	0	0	0	0	1			
27	n/a	1	1	1	1	1	1	1	1	1	1			
28	n/a	1	1	1	1	1	1	1	1	1	1			
29	n/a	1	1	1	1	1	1	1	1	1	1			
30	n/a	0	0	0	0	0	1	0	0	0	0			
31	n/a	1	1	1	1	1	1	1	1	1	1			
32	n/a	1	1	1	1	1	1	1	1	1	1			
33	n/a	1	1	1	1	1	1	1	1	1	1			
34	n/a	0	0	0	1	0	0	1	0	1	1			
35	n/a	1	1	1	1	1	1	1	1	1	1			
36	n/a	1	1	1	0	1	1	1	1	0	1			
37	n/a	0	0	0	0	0	0	0	0	0	0			
38	n/a	1	1	1	1	1	1	1	1	1	1			
39	n/a	0	0	0	0	0	0	0	0	0	0			
40	n/a	1	1	1	1	1	1	1	1	1	1			
41	n/a	1	1	1	1	1	1	1	1	1	1			
42	n/a	0	0	0	0	0	0	0	0	0	0			
43	n/a	1	1	0	1	1	1	1	1	1	0			
44	n/a	1	1	1	1	1	1	1	1	1	1			
45	n/a	0	0	0	0	0	0	0	0	0	0			
46	n/a	1	1	1	1	1	1	1	1	1	1			
47	n/a	1	1	1	1	1	1	1	1	1	1			
48	n/a	0	0	0	0	0	0	0	0	0	0			
49	n/a	1	1	1	1	1	1	1	1	1	1			
50	n/a	0	0	0	0	0	0	0	0	0	0			

n/a - not applicable

Procedure 7 – Discrete characteristics – Analysis

→ Pairwise combinations per appraiser

- One appraiser checks one part three times
- Each test result is compared against the other two test results
- Only agreements are counted



- Agreement 1-2, 1-3, 2-1, 2-3, 3-1, 3-2 → $A_{xA} = 6$
- Agreement 1-2, 2-1 → $A_{xA} = 2$
- Agreement 2-3, 3-2 → $A_{xA} = 2$
- Agreement 1-2, 1-3, 2-1, 2-3, 3-1, 3-2 → $A_{xA} = 6$

Pairwise combinations are counted according to the same principle

→ all appraisers

$$\rightarrow A_{xBxC} = 44$$



→ each test result of each appraiser against the corresponding reference

$$\rightarrow A_{1 \times R} = 0 \text{ or } 2$$

Procedure 7 – Discrete characteristics – Analysis

Number of pair-wise identical combinations per test object i (i = 1, ... N ₀)																								
Categories: 0 - Not OK 1 - OK												A x A	B x B	C x C	A x B x C	A-1 x Ref	A-2 x Ref	A-3 x Ref	B-1 x Ref	B-2 x Ref	B-3 x Ref	C-1 x Ref	C-2 x Ref	C-3 x Ref
Test Object No.	Reference	Appraiser – Trial																						
		A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3														
1	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
2	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
3	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2		
4	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2		
5	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2		
6	1	1	1	0	1	1	0	1	0	0	2	2	2	32	2	2	0	2	2	0	2	0		
7	1	1	1	1	1	1	1	1	1	0	6	6	2	56	2	2	2	2	2	2	0	2		
8	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
9	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2		
10	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
11	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
12	0	0	0	0	0	0	0	0	1	0	6	6	2	56	2	2	2	2	2	2	0	2		
13	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
14	1	1	1	0	1	1	1	1	0	0	2	6	2	36	2	2	0	2	2	2	0	0		
15	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
16	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
17	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
18	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
19	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
20	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
21	1	1	1	0	1	0	1	0	1	0	2	2	2	32	2	2	0	2	0	2	0	0		
22	0	0	0	1	0	1	0	1	1	0	2	2	2	32	2	2	0	2	0	2	0	2		
23	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
24	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2		
25	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2		
26	0	0	1	0	0	0	0	0	0	1	2	6	2	44	2	0	2	2	2	2	2	0		

Procedure 7 – Discrete characteristics – Analysis

- From the pairwise combinations determine
- Sum of all observed decisions that are in agreement
 - Sum of all possible decisions that could be in agreement
 - Percentage of observed decisions that are in agreement

Number of pair-wise identical combinations per test object i (i = 1, ... N ₀)																								
Categories:		0 - Not OK 1 - OK									A x A	B x B	C x C	A x B x C	A-1 x Ref	A-2 x Ref	A-3 x Ref	B-1 x Ref	B-2 x Ref	B-3 x Ref	C-1 x Ref	C-2 x Ref	C-3 x Ref	
Test Object No.	Reference	Appraiser – Trial																						
		A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3														
1	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2	
2	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2	
3	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2	
4	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2	
49	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2	
50	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2	
Observed number of pair-wise identical combinations n*												268	280	260	3272	100	96	88	100	96	94	96	86	88
Possible number of pair-wise identical combinations N*												300	300	300	3600	100	100	100	100	100	100	100	100	100
Observed fraction of pair-wise identical combinations P _{Obs} = n* / N*												0.8933	0.9333	0.8667	0.9089	1.0000	0.9600	0.8800	1.0000	0.9600	0.9400	0.9600	0.8600	0.8800

Procedure 7 – Discrete characteristics – Analysis

- From the individual decisions per part determine
 - Sum and percentage of all OK assessments
 - Sum and percentage of all NOK assessments
 - Assuming these assessments are correct, it is possible to calculate the expected proportion of (random) assessments in agreement

Number of pair-wise identical combinations per test object i (i = 1, ... N ₀)												
Categories:		Appraiser – Trial									A x A	
Test Object No.	Reference											
		A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3		
1	1	1	1	1	1	1	1	1	1	1	6	6
2	1	1	1	1	1	1	1	1	1	1	6	6
3	0	0	0	0	0	0	0	0	0	0	6	6
Observed number of evaluations per category n _k (k = 1, ... N _C)		50	47	51	148	32	32	34	32	32	31	32
		100	103	99	302	68	68	66	68	68	69	68
Total number of evaluations N		150	150	150	450	100	100	100	100	100	100	100
Observed fraction of evaluations per category n _k / N (k = 1, ... N _C)		0.3333	0.3133	0.34	0.3289	0.32	0.32	0.34	0.32	0.32	0.31	0.32
		0.6667	0.6867	0.66	0.6711	0.68	0.68	0.66	0.68	0.68	0.69	0.68
Expected fraction of randomly identical evaluations P _{Exp} = Σ _k (n _k /N) ²		0.5556	0.5697	0.5512	0.5586	0.5648	0.5648	0.5512	0.5648	0.5648	0.5722	0.5648

Procedure 7 – Discrete characteristics – Analysis

- Calculate a kappa value from the observed and expected percentages
- The difference between the observed agreements P_{Obs} and the expected (random) agreements P_{Exp} yields the proportion of “observed non-random agreements” $P_{Obs} - P_{Exp}$
 - The difference between the expected (random) agreements P_{Exp} and 100% yields the proportion of “possible non-random agreements” $1 - P_{Exp}$

$$\kappa = \frac{P_{Obs} - P_{Exp}}{1 - P_{Exp}} = \frac{\text{Observed non-random agreements}}{\text{Possible non-random agreements}}$$

Procedure 7 – Discrete characteristics – Analysis

- Calculate the kappa values, use respective mean values for the assessment of agreement with the reference

Number of pair-wise identical combinations per test object i (i = 1, ... N ₀)																									
Categories:		0 - Not OK 1 - OK									A x A	B x B	C x C	A x B x C	A-1 x Ref	A-2 x Ref	A-3 x Ref	B-1 x Ref	B-2 x Ref	B-3 x Ref	C-1 x Ref	C-2 x Ref	C-3 x Ref		
Test Object No.	Reference	Appraiser – Trial																							
		A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3															
1	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2		
2	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2		
3	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2		
4	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2		
5	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2		
48	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2		
49	1	1	1	1	1	1	1	1	1	1	6	6	6	72	2	2	2	2	2	2	2	2	2		
50	0	0	0	0	0	0	0	0	0	0	6	6	6	72	2	2	2	2	2	2	2	2	2		
Observed fraction of pair-wise identical combinations P _{Obs} = n* / N*											0.8933	0.9333	0.8667	0.9089	1.0000	0.9600	0.8800	1.0000	0.9600	0.9400	0.9600	0.8600	0.8800		
Expected fraction of randomly identical evaluations P _{Exp} = Σ _k (n _k /N) ²											0.5556	0.5697	0.5512	0.5586	0.5648	0.5648	0.5512	0.5648	0.5648	0.5722	0.5648	0.5578	0.5512		
Kappa: $\frac{P_{Obs} - P_{Exp}}{1 - P_{Exp}} = \kappa$											0.7600	0.8451	0.7029	0.7936	1.0000	0.9081	0.7326	1.0000	0.9081	0.8597	0.9081	0.6834	0.7326		
Kappa: Each appraiser against reference (mean values)														0.8802			0.9226			0.7747					
Kappa: All appraisers against reference (mean value)																	0.8592								

Procedure 7 – Discrete characteristics – Analysis

- The smallest kappa value determines the overall result

Number of pair-wise identical combinations per test object i (i = 1, ... N ₀)																							
Categories: 0 - Not OK 1 - OK																							
Test Object No.	reference	Appraiser – Trial									A x A	B x B	C x C	A x B x C	A-1 x Ref	A-2 x Ref	A-3 x Ref	B-1 x Ref	B-2 x Ref	B-3 x Ref	C-1 x Ref	C-2 x Ref	C-3 x Ref
		A-1	A-2	A-3	B-1	B-2	B-3	C-1	C-2	C-3													
Kappa: $\frac{P_{Obs} - P_{Exp}}{1 - P_{Exp}} = \kappa$		0.7600	0.8451	0.7029	0.7936	1.0000	0.9081	0.7326	1.0000	0.9081	0.8597	0.9081	0.6834	0.7326									
Kappa: Each appraiser against reference (mean values)					0.8802			0.9226			0.7747												
Kappa: All appraisers against reference (mean value)								0.8592															
Appraiser name		Symbol	κ (Kappa)			$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable	κ (Kappa)			$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable									
Miller		A	0.7600				X		0.8802				X										
Smith		B	0.8451				X		0.9226		X												
King		C	0.7029				X		0.7747				X										
		Between appraisers without reference							All appraisers against reference														
all			0.7936				X		0.8592				X										
Total Result		Minimum of all results: Kappa = 0.7029																					
Kappa ≥ 0.90 : <input type="checkbox"/> capable		0.70 \leq Kappa $<$ 0.90: <input checked="" type="checkbox"/> conditionally capable		Kappa $<$ 0.70: <input type="checkbox"/> not capable																			

1




Procedure 7 – Discrete characteristics

BOSCH Quality Management		Test Process Analysis Procedure 7																																																																																																																																																																																																																																															
Product / Test Object Product: <u>Housing</u> Part: <u>Cover</u> Part / Drawing No.: <u>A 111 999 222</u> Revision: <u>05 / 02/29/2009</u>		Characteristic: Designation: <u>Surface quality</u> Characteristic No.: <u>15</u> <input type="checkbox"/> Continuous Characteristic Nominal Value: <u>n/a</u> Upper Limit: <u>n/a</u> Lower Limit: <u>n/a</u> Tolerance: <u>n/a</u> Unit: <u>n/a</u> <input checked="" type="checkbox"/> Discrete Characteristic																																																																																																																																																																																																																																															
Test Method: <u>Visual inspection, manually, room temperature 20.2°C, light inten:</u>																																																																																																																																																																																																																																																	
Test Scenario Number of reference parts: $N_0 = 50$ Number of appraisers: $N_A = 3$ Number of trials per appraiser: $N_T = 3$ Number of evaluation categories: $N_E = 2$		Evaluation Categories $0 = \text{Not OK}$ $1 = \text{OK}$																																																																																																																																																																																																																																															
Test Data: <u>See sheet 2 ff</u>																																																																																																																																																																																																																																																	
Analysis																																																																																																																																																																																																																																																	
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Appraiser name</th> <th rowspan="2">Symbol</th> <th colspan="4">Within appraiser without reference</th> <th colspan="4">Each appraiser against reference</th> </tr> <tr> <th>κ (Kappa)</th> <th>$\kappa \geq 0.90$ capable</th> <th>$0.70 \leq \kappa < 0.90$ conditionally capable</th> <th>$\kappa < 0.70$ not capable</th> <th>κ (Kappa)</th> <th>$\kappa \geq 0.90$ capable</th> <th>$0.70 \leq \kappa < 0.90$ conditionally capable</th> <th>$\kappa < 0.70$ not capable</th> </tr> </thead> <tbody> <tr> <td><u>Miller</u></td> <td><u>A</u></td> <td><u>0.7600</u></td> <td></td> <td><u>X</u></td> <td></td> <td><u>0.8802</u></td> <td></td> <td><u>X</u></td> <td></td> </tr> <tr> <td><u>Smith</u></td> <td><u>B</u></td> <td><u>0.8451</u></td> <td></td> <td><u>X</u></td> <td></td> <td><u>0.9226</u></td> <td><u>X</u></td> <td></td> <td></td> </tr> <tr> <td><u>King</u></td> <td><u>C</u></td> <td><u>0.7029</u></td> <td></td> <td><u>X</u></td> <td></td> <td><u>0.7747</u></td> <td></td> <td><u>X</u></td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr> <td colspan="2"> </td> <td colspan="4">Between appraisers without reference</td> <td colspan="4">All appraisers against reference</td> </tr> <tr> <td><u>all</u></td> <td> </td> <td><u>0.7936</u></td> <td></td> <td><u>X</u></td> <td></td> <td><u>0.8592</u></td> <td></td> <td><u>X</u></td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr> <td colspan="2"> </td> <td colspan="4">Between appraisers without reference</td> <td colspan="4">All appraisers against reference</td> </tr> <tr> <td><u>all</u></td> <td> </td> <td><u>0.7936</u></td> <td></td> <td><u>X</u></td> <td></td> <td><u>0.8592</u></td> <td></td> <td><u>X</u></td> <td></td> </tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>				Appraiser name	Symbol	Within appraiser without reference				Each appraiser against reference				κ (Kappa)	$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable	κ (Kappa)	$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable	<u>Miller</u>	<u>A</u>	<u>0.7600</u>		<u>X</u>		<u>0.8802</u>		<u>X</u>		<u>Smith</u>	<u>B</u>	<u>0.8451</u>		<u>X</u>		<u>0.9226</u>	<u>X</u>			<u>King</u>	<u>C</u>	<u>0.7029</u>		<u>X</u>		<u>0.7747</u>		<u>X</u>																																																						Between appraisers without reference				All appraisers against reference				<u>all</u>		<u>0.7936</u>		<u>X</u>		<u>0.8592</u>		<u>X</u>																																																						Between appraisers without reference				All appraisers against reference				<u>all</u>		<u>0.7936</u>		<u>X</u>		<u>0.8592</u>		<u>X</u>																																																			
Appraiser name	Symbol	Within appraiser without reference				Each appraiser against reference																																																																																																																																																																																																																																											
		κ (Kappa)	$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable	κ (Kappa)	$\kappa \geq 0.90$ capable	$0.70 \leq \kappa < 0.90$ conditionally capable	$\kappa < 0.70$ not capable																																																																																																																																																																																																																																								
<u>Miller</u>	<u>A</u>	<u>0.7600</u>		<u>X</u>		<u>0.8802</u>		<u>X</u>																																																																																																																																																																																																																																									
<u>Smith</u>	<u>B</u>	<u>0.8451</u>		<u>X</u>		<u>0.9226</u>	<u>X</u>																																																																																																																																																																																																																																										
<u>King</u>	<u>C</u>	<u>0.7029</u>		<u>X</u>		<u>0.7747</u>		<u>X</u>																																																																																																																																																																																																																																									
		Between appraisers without reference				All appraisers against reference																																																																																																																																																																																																																																											
<u>all</u>		<u>0.7936</u>		<u>X</u>		<u>0.8592</u>		<u>X</u>																																																																																																																																																																																																																																									
		Between appraisers without reference				All appraisers against reference																																																																																																																																																																																																																																											
<u>all</u>		<u>0.7936</u>		<u>X</u>		<u>0.8592</u>		<u>X</u>																																																																																																																																																																																																																																									
Total Result Kappa ≥ 0.90 : <input type="checkbox"/> capable 0.70 \leq Kappa < 0.90 : <input checked="" type="checkbox"/> conditionally capable Kappa < 0.70 : <input type="checkbox"/> not capable		Minimum of all results: Kappa = <u>0.7029</u> Kappa ≥ 0.90 : <input type="checkbox"/> capable 0.70 \leq Kappa < 0.90 : <input checked="" type="checkbox"/> conditionally capable Kappa < 0.70 : <input type="checkbox"/> not capable																																																																																																																																																																																																																																															
Comment: <u>none</u>																																																																																																																																																																																																																																																	
Date: <u>02/29/2009</u> Department: <u>W025</u> Name: <u>J. Q. Public</u> Signature: <u>J. Q. Public</u>																																																																																																																																																																																																																																																	

Procedure 6&7 – Stability or repetition?

- There are no defined requirements for stability checks for test process capability
- An np- or p-chart as used in SPC would be an obvious possibility
- However, these charts typically use sample sizes $n \geq 50$
- So stability monitoring would essentially be an ongoing repetition of procedure 7
- Some typical criteria for a repeat test:
 - When commissioning a new, overhauled or repaired test equipment; after maintenance work
 - After technical changes to an test equipment
 - After additions or significant changes to reference standards
 - After a change of test process conditions or appraisers
 - See also criteria for repeating measurement process capability studies

Non-capable measurement or test processes



Observe sequence :

- ➔ **Optimize measurement processes**
 - ➔ **Measuring equipment, standards**
 - ➔ **Measurement procedure, strategy**
 - ➔ **Environmental conditions**
 - ➔ **Object of measurement**
 - ➔ **Appraisers, instructions**
 - ➔ **Purchase more precise measuring system**
- ➔ **Look at characteristic, tolerance, and measurement process**

**Many thanks for your interest and
cooperation**



Zoltan Janosy
zoltan.janosy@ttq.ro
T&T Quality Engineering RO SRL